CONEX-LDS

Electronic Autocollimator



Newport®
Experience | Solutions

Command Interface Manual

V1.0.x

For Motion, Think Newport™

Table of Contents

1.0 Introduction 1
1.1 Purpose 1
1.2 Overview 1
1.3 Location 2
1.4 Possible uses of Newport.CONEXLDS.CommandInterface.dll 2

2.0 Command Interface 3
2.1 Constructor 3
2.2 Functions 3
2.2.1 General 3
- OpenInstrument 3
- CloseInstrument 3
- GetDevices 3
- WriteToInstrument 4

2.2.2 Commands 4
CD 4
GP 5
GX_Get 5
GX_Set 5
GY_Get 6
GY_Set 6
ID_Get 6
ID_Set 7
LB_Get 7
LB_Set 7
LF_Get 8
LF_Set 8
PW_Get 8
PW_Set 9
PX_Get 9
PX_Set 9
PY_Get 10
PY_Set 10
RG_Get 10
RG_Set 11
RS 11
RS485 11
SA_Get 12

SA_Set 12
SL_Get 12
SL_Set 13
SR_Get 13
SR_Set 13
SU_Get 14
SU_Set 14
TB 14
TE 15
TS 15
VE 15
ZT 16

3.0 Python example 17

Service Form 21

CONEX-LDS
Electronic Autocollimator

1.0 Introduction

1.1 Purpose

The purpose of this document is to provide the method syntax of each command to communicate with the CONEX-LDS autocollimator exposed in assembly Newport.CONEXLDS.CommandInterface.dll. This .Net assembly is designed and developed by Newport. This DLL is used by CONEX-LDS applet to communicate with the CONEX-LDS autocollimator.

1.2 Overview

Command Interface DLL is a generic name that refers to a DLL used to communicate with an instrument. Typically this DLL exposes all the commands the instrument supports. These commands are exposed as function calls of the Command Interface DLL.

Newport.CONEXLDS.CommandInterface.dll is the assembly used for communicating with the CONEX-LDS autocollimator. This assembly is installed with the CONEX-LDS applet.

NOTES

Each function name is defined with the command code "AA".

For more information on each command function, refer to the CONEX-LDS programmer's manual.

1.3 Location

Newport.CONEXLDS.CommandInterface.dll is located with the following path: \Newport\MotionControl\CONEX-LDS\Bin\Newport.CONEXLDS.CommandInterface.dll

1.4 Possible uses of Newport.CONEXLDS.CommandInterface.dll

Newport.CONEXLDS.CommandInterface.dll is used by CONEX-LDS applet for communicating with the CONEX-LDS autocollimator. The same DLL can be used as a reusable software component for creating Python scripts or LabVIEW VIs.

2.0 Command Interface

2.1 Constructor

CONEXLDS()

The constructor is used to create an instance of the CONEX-LDS device.

2.2 Functions

2.2.1 General

- **OpenInstrument**

Syntax

int OpenInstrument(string strDeviceKey)

string strDeviceKey: the device key is a serial COM port

return: 0 = successful or -1 = failure

Decription

This function allows opening communication with the selected device. If the opening failed, the returned code is -1.

- **CloseInstrument**

Syntax

int CloseInstrument()

return: 0 = successful or -1 = failure

Decription

This function allows closing communication with the selected device. If the closing failed, the returned code is -1.

- **GetDevices**

Syntax

string[] GetDevices()

return: list of strings that contains the accessible COM ports

Decription

This function returns the list of connected devices available to communicate.

- **WriteToInstrument**

Syntax

int WriteToInstrument(string command, ref string resp, int stage)

command: Instrument command

resp: Response of the command

stage: Instrument Stage

return: function error

Decription

This Overridden function Queries or writes the command issued by the user to the instrument.

2.2.2 Commands

CD

Syntax

int CD(int controllerAddress, out string FactoryCalibrationInformation, out string errstring)

controllerAddress: controllerAddress

FactoryCalibrationInformation: FactoryCalibrationInformation

errString: The failure reason

return: 0 in success and -1 on failure

Description

This function is used to process synchrounous CD Get command which is used to Get factory calibration information. Refer to the Controller's User's Manual for further information..

GP

Syntax

int GP(int controllerAddress, out double PositionX, out double PositionY, out double LaserPower, out string errstring)

controllerAddress: controllerAddress

PositionX: PositionX

PositionY: PositionY

LaserPower: LaserPower

errString: The failure reason

return: 0 in success and -1 on failure

Description

This function is used to process synchrounous GP Get command, which is used to Get positions and power. Refer to the CONEX-LDS User's Manual for more detailed information on the command..

GX_Get

Syntax

int GX_Get(int controllerAddress, out double GainX, out string errstring)

controllerAddress: controllerAddress

GainX: GainX

errString: The failure reason

return: 0 in success and -1 on failure

Description

This function is used to process synchrounous GX Get command which is used to Get gain for analog image of X channel. Refer to the CONEX-LDS User's Manual for more information on this command

GX_Set

Syntax

int GX_Set(int controllerAddress, double GainX, out string errstring)

controllerAddress: controllerAddress

GainX: GainX

errString: The failure reason

return: 0 in success and -1 on failure

Description

This function is used to process synchrounous GX Set command which is used to Set gain for analog image of X channel. Refer to the CONEX-LDS User's Manual for more information on this command

GY_Get

Syntax

int GY_Get(int controllerAddress, out double GainY, out string errstring)

controllerAddress: controllerAddress

GainY: GainY

errString: The failure reason

return: 0 in success and -1 on failure

Description

This function is used to process synchrounous GY Get command which is used to Get gain for analog image of Y channel. Refer to the CONEX-LDS User's Manual for more information on this command

GY_Set

Syntax

int GY_Set(int controllerAddress, double GainY, out string errstring)

controllerAddress: controllerAddress

GainY: GainY

errString: The failure reason

return: 0 in success and -1 on failure

Description

This function is used to process synchrounous GY Set command which is used to Set gain for analog image of Y channel. Refer to the CONEX-LDS User's Manual for more information on this command

ID_Get

Syntax

int ID_Get(int controllerAddress, out string ControllerIdentifier, out string errstring)

controllerAddress: controllerAddress

ControllerIdentifier: ControllerIdentifier

errString: The failure reason

return: 0 in success and -1 on failure

Description

This function is used to process synchrounous ID Get command which is used to Get controller identifier. Refer to the CONEX-LDS User's Manual for more information on this command

ID_Set

Syntax

int ID_Set(int controllerAddress, string ControllerIdentifier, out string errstring)

controllerAddress: controllerAddress

ControllerIdentifier: ControllerIdentifier

errString: The failure reason

return: 0 in success and -1 on failure

Description

This function is used to process synchrounous ID Set command which is used to Set controller identifier. Refer to the CONEX-LDS User's Manual for more information on this command

LB_Get

Syntax

int LB_Get(int controllerAddress, out int LaserState, out string errstring)

controllerAddress: controllerAddress

LaserState: LaserState

errString: The failure reason

return: 0 in success and -1 on failure

Description

This function is used to process synchrounous LB Get command which is used to Power ON/ Power OFF the laser. Refer to the CONEX-LDS User's Manual for more information on this command

LB_Set

Syntax

int LB_Set(int controllerAddress, int LaserState, out string errstring)

controllerAddress: controllerAddress

LaserState: LaserState

errString: The failure reason

return: 0 in success and -1 on failure

Description

This function is used to process synchrounous LB Set command which is used to Power ON/ Power OFF the laser. Refer to the CONEX-LDS User's Manual for more information on this command

LF_Get

Syntax

int LF_Get(int controllerAddress, out float Frequency, out string errstring)

controllerAddress: controllerAddress

Frequency: Frequency

errString: The failure reason

return: 0 in success and -1 on failure

Description

This function is used to process synchrounous LF Get command which is used to Get the low pass filter frequency. Refer to the CONEX-LDS User's Manual for more information on this command

LF_Set

Syntax

int LF_Set(int controllerAddress, float Frequency, out string errstring)

controllerAddress: controllerAddress

Frequency: Frequency

errString: The failure reason

return: 0 in success and -1 on failure

Description

This function is used to process synchrounous LF Set command which is used to Set the low pass filter frequency. Refer to the CONEX-LDS User's Manual for more information on this command

PW_Get

Syntax

int PW_Get(int controllerAddress, out int ConfigurationState, out string errstring)

controllerAddress: controllerAddress

ConfigurationState: ConfigurationState

errString: The failure reason

return: 0 in success and -1 on failure

Description

This function is used to process synchrounous PW Get command which is used to Enter/Leave the CONFIGURATION state. Refer to the CONEX-LDS User's Manual for more information on this command

PW_Set

Syntax

int PW_Set(int controllerAddress, int ConfigurationState, out string errstring)

controllerAddress: controllerAddress

ConfigurationState: ConfigurationState

errString: The failure reason

return: 0 in success and -1 on failure

Description

This function is used to process synchrounous PW Set command which is used to Enter/Leave the CONFIGURATION state. Refer to the CONEX-LDS User's Manual for more information on this command

PX_Get

Syntax

int PX_Get(int controllerAddress, out double CalibrationCoefficientX, out string errstring)

controllerAddress: controllerAddress

CalibrationCoefficientX: CalibrationCoefficientX

errString: The failure reason

return: 0 in success and -1 on failure

Description

This function is used to process synchrounous PX Get command which is used to Get the calibration value for X channel. Refer to the CONEX-LDS User's Manual for more information on this command

PX_Set

Syntax

int PX_Set(int controllerAddress, double CalibrationCoefficientX, out string errstring)

controllerAddress: controllerAddress

CalibrationCoefficientX: CalibrationCoefficientX

errString: The failure reason

return: 0 in success and -1 on failure

Description

This function is used to process synchrounous PX Set command which is used to Set the calibration value for X channel. Refer to the CONEX-LDS User's Manual for more information on this command

PY_Get

Syntax

int PY_Get(int controllerAddress, out double CalibrationCoefficientY, out string errstring)

controllerAddress: controllerAddress

CalibrationCoefficientY: CalibrationCoefficientY

errString: The failure reason

return: 0 in success and -1 on failure

Description

This function is used to process synchrounous PY Get command which is used to Get the calibration value for Y channel. Refer to the CONEX-LDS User's Manual for more information on this command

PY_Set

Syntax

int PY_Set(int controllerAddress, double CalibrationCoefficientY, out string errstring)

controllerAddress: controllerAddress

CalibrationCoefficientY: CalibrationCoefficientY

errString: The failure reason

return: 0 in success and -1 on failure

Description

This function is used to process synchrounous PY Set command which is used to Set the calibration value for Y channel. Refer to the CONEX-LDS User's Manual for more information on this command

RG_Get

Syntax

int RG_Get(int controllerAddress, out int Range, out string errstring)

controllerAddress: controllerAddress

Range: Range

errString: The failure reason

return: 0 in success and -1 on failure

Description

This function is used to process synchrounous RG Get command which is used to Get the range value. Refer to the CONEX-LDS User's Manual for more information on this command

RG_Set

Syntax

int RG_Set(int controllerAddress, int Range, out string errstring)

controllerAddress: controllerAddress

Range: Range

errString: The failure reason

return: 0 in success and -1 on failure

Description

This function is used to process synchrounous RG Set command which is used to Set the range value. Refer to the CONEX-LDS User's Manual for more information on this command

RS

Syntax

int RS(int controllerAddress, out string errstring)

controllerAddress: controllerAddress

errString: The failure reason

return: 0 in success and -1 on failure

Description

This function is used to process synchrounous RS Set command which is used to Reset the controller. Refer to the CONEX-LDS User's Manual for more information on this command

RS485

Syntax

int RS485(int controllerAddress, out string errstring)

controllerAddress: controllerAddress

errString: The failure reason

return: 0 in success and -1 on failure

Description

This function is used to process synchrounous RS## Set command which is used to Reset the controller's address to 1. Refer to the CONEX-LDS User's Manual for more information on this command

SA_Get

Syntax

int SA_Get(int controllerAddress, out int Address, out string errstring)

controllerAddress: controllerAddress

Address: Address

errString: The failure reason

return: 0 in success and -1 on failure

Description

This function is used to process synchrounous SA Get command which is used to Get the controller's RS-485 address. Refer to the CONEX-LDS User's Manual for more information on this command

SA_Set

Syntax

int SA_Set(int controllerAddress, int Address, out string errstring)

controllerAddress: controllerAddress

Address: Address

errString: The failure reason

return: 0 in success and -1 on failure

Description

This function is used to process synchrounous SA Set command which is used to Set the controller's RS-485 address. Refer to the CONEX-LDS User's Manual for more information on this command

SL_Get

Syntax

int SL_Get(int controllerAddress, out int LowlevelPowerThreshold, out string errstring)

controllerAddress: controllerAddress

LowlevelPowerThreshold: LowlevelPowerThreshold

errString: The failure reason

return: 0 in success and -1 on failure

Description

This function is used to process synchrounous SL Get command which is used to Get low level power threshold for valid measurements. Refer to the CONEX-LDS User's Manual for more information on this command

SL_Set

Syntax

int SL_Set(int controllerAddress, int LowlevelPowerThreshold, out string errstring)

controllerAddress: controllerAddress

LowlevelPowerThreshold: LowlevelPowerThreshold

errString: The failure reason

return: 0 in success and -1 on failure

Description

This function is used to process synchrounous SL Set command which is used to Set low level power threshold for valid measurements. Refer to the CONEX-LDS User's Manual for more information on this command

SR_Get

Syntax

int SR_Get(int controllerAddress, out int HighlevelPowerThreshold, out string errstring)

controllerAddress: controllerAddress

HighlevelPowerThreshold: HighlevelPowerThreshold

errString: The failure reason

return: 0 in success and -1 on failure

Description

This function is used to process synchrounous SR Get command which is used to Get high level power threshold for valid measurements. Refer to the CONEX-LDS User's Manual for more information on this command

SR_Set

Syntax

int SR_Set(int controllerAddress, int HighlevelPowerThreshold, out string errstring)

controllerAddress: controllerAddress

HighlevelPowerThreshold: HighlevelPowerThreshold

errString: The failure reason

return: 0 in success and -1 on failure

Description

This function is used to process synchrounous SR Set command which is used to Set high level power threshold for valid measurements. Refer to the CONEX-LDS User's Manual for more information on this command

SU_Get

Syntax

int SU_Get(int controllerAddress, out string Units, out string errstring)

controllerAddress: controllerAddress

Units: Units

errString: The failure reason

return: 0 in success and -1 on failure

Description

This function is used to process synchrounous SU Get command to set the the measurement units. Refer to the CONEX-LDS User's Manual for more information on this command

SU_Set

Syntax

int SU_Set(int controllerAddress, string Units, out string errstring)

controllerAddress: controllerAddress

Units: Units

errString: The failure reason

return: 0 in success and -1 on failure

Description

This function is used to process synchrounous SU Set command to set the the measurement units. Refer to the CONEX-LDS User's Manual for more information on this command

TB

Syntax

int TB(int controllerAddress, string inError, out string outError, out string errString)

controllerAddress: Address of Controller

inError: inError.

outError: outError

errString: The failure reason

return: 0 in success and -1 on failure

Decription

This function is used to process synchrounous TB Get command which explains the meaning of the error string. Refer to the CONEX-LDS Controller's manual to get the command description.

TE

Syntax

int TE(int controllerAddress, out string LastCommandError, out string errstring)

controllerAddress: controllerAddress

LastCommandError: LastCommandError

errString: The failure reason

return: 0 in success and -1 on failure

Description

This function is used to process synchrounous TE Get command which is used to Get the last command error. Refer to the CONEX-LDS User's Manual for more information on this command

TS

Syntax

int TS(int controllerAddress, out string ErrorCode, out string StatusCode, out string errstring)

controllerAddress: controllerAddress

ErrorCode: ErrorCode

StatusCode: StatusCode

errString: The failure reason

return: 0 in success and -1 on failure

Description

This function is used to process synchrounous TS Get command which is used to Get the positioner error and current controller state. Refer to the CONEX-LDS User's Manual for more information on this command

VE

Syntax

int VE(int controllerAddress, out string ControllerVersion, out string errstring)

controllerAddress: controllerAddress

ControllerVersion: ControllerVersion

errString: The failure reason

return: 0 in success and -1 on failure

Description

This function is used to process synchrounous VE Get command which is used to Get controller revision information. Refer to the CONEX-LDS User's Manual for more information on this command

ZT

Syntax

int ZT(int controllerAddress, out List<string> ConfigurationParameters, out string errstring)

controllerAddress: controllerAddress

ConfigurationParameters: ConfigurationParameters

errString: The failure reason

return: 0 in success and -1 on failure

Description

This function is used to process synchrounous ZT Get command which is used to Get all controller parameters. Refer to the CONEX-LDS User's Manual for more information on this command

3.0 Python example

```
#==========================================================================
# Newport Proprietary and Confidential    Newport Corporation @2012
#
# No part of this file in any format, with or without modification
# shall be used, copied or distributed without the express written
# consent of Newport Corporation.
#
# Description: This is a Python Script to access CONEX-LDS library
#==========================================================================
=
# Initialization Start
# The script within Initialization Start and Initialization End is needed
for
# properly initializing Command Interface for Conex-LDS instrument.
# The user should copy this code as is and specify correct paths here.
import sys
# Command Interface DLL can be found here.
print "Adding location of Newport.CONEXLDS.CommandInterface.dll to
sys.path"
sys.path.append(r'C:\Program Files\Newport\MotionControl\CONEX-LDS\Bin')

# The CLR module provide functions for interacting with the underlying
# .NET runtime
import clr
# Add reference to assembly and import names from namespace
clr.AddReferenceToFile("Newport.CONEXLDS.CommandInterface.dll")
from CommandInterfaceConexLDS import *

import System
#==========================================================================

# Constant
ON = 1
OFF = 0

#***************************************************
# Procedure to open communication with instrument.
#***************************************************
def CONEXLDS_Open (instrumentKey):
      # Create a CONEX-LDS instance
      LDS = ConexLDS()

      print 'Instrument Key=>', instrumentKey
      ret = LDS.OpenInstrument(instrumentKey)
      print 'OpenInstrument => ', ret

      return LDS

#***************************************************
# Procedure to close communication.
#***************************************************
def CONEXLDS_Close(LDS):
      LDS.CloseInstrument()

#***************************************************
# Procedure to get the controller version (VE)
#***************************************************
def CONEXLDS_GetControllerVersion (LDS, address, flag):
```

```
	result, version, errString = LDS.VE(address)
	if flag == 1:
		if result == 0 :
			print 'CONEX-LDS firmware version => ', version
		else:
			print 'VE Error => ',errString
	return result, version

#***********************************************
# Procedure to get the laser status (GP Command)
#***********************************************
def CONEXLDS_GetPositionsAndLightLevel (LDS, address, flag):
	# Get X, Y positions and light level Using GP Command
	result, posX, posY, lightLevel, errString = LDS.GP(address)
	if flag == 1:
		if result == 0 :
			print 'Position X => ', posX
			print 'Position Y => ', posY
			print 'Light level => ',lightLevel, "%"
	else:
			print 'GP Error => ',errString
	return result, posX, posY, lightLevel

#***********************************************
# Procedure to get the laser status (LB? Command)
#***********************************************
def CONEXLDS_GetLaserStatus (LDS, address, flag):
	result, laserStatus, errString = LDS.LB_Get(address)
	if flag == 1:
		if result == 0 :
			print 'Laser status => ', laserStatus
		else:
			print 'LB_Get Error => ',errString
	return result, laserStatus

#***********************************************
# Procedure to set the laser status (LB Command)
#***********************************************
def CONEXLDS_SetLaserStatus (LDS, address, laserStatus, flag):
	result, errString = LDS.LB_Set(address, laserStatus)
	if flag == 1:
		if result != 0 :
			print 'LB_Set Error => ',errString
	return result

#***********************************************
# Main
#***********************************************

# Initialization
instrument="COM19"
displayFlag = 1
address = 1

# Create a CONEX-LDS interface and open communication.
LDS = CONEXLDS_Open(instrument)

# Get controller revision information
result, version = CONEXLDS_GetControllerVersion(LDS, address, displayFlag)

# Get laser status
result, iLaserStatus = CONEXLDS_GetLaserStatus(LDS, address, displayFlag)
if result == 0 :
	# If the laser is OFF then turn the laser ON
```

```
      # Check and refresh the laser status
      if iLaserStatus == OFF:
            print 'Laser is OFF'
            result = CONEXLDS_SetLaserStatus(LDS, address, ON,
displayFlag)
            result, iLaserStatus = CONEXLDS_GetLaserStatus(LDS, address,
displayFlag)

# Get positions
if iLaserStatus == ON:
      print 'Laser is ON'
      # Get X, Y positions and light level
      returnValue, positionX, positionY, lightLevel =
CONEXLDS_GetPositionsAndLightLevel(LDS, address, displayFlag)

# close communication.
CONEXLDS_Close(LDS)

print 'End of script'
```

Service Form

Your Local Representative

Tel.: _____

Fax: _____

Name: _____

Company: _____

Address: _____

Country: _____

P.O. Number: _____

Item(s) Being Returned: _____

Model#: _____

Return authorization #: _____
(Please obtain prior to return of item)

Date: _____

Phone Number: _____

Fax Number: _____

Serial #: _____

Description: _____

Reasons of return of goods (please list any specific problems): _____



Newport®

Experience | Solutions

Visit Newport Online at:
www.newport.com

North America & Asia
Newport Corporation
1791 Deere Ave.
Irvine, CA 92606, USA

Sales
Tel.: (800) 222-6440
e-mail: sales@newport.com

Technical Support
Tel.: (800) 222-6440
e-mail: tech@newport.com

Service, RMAs & Returns
Tel.: (800) 222-6440
e-mail: rma.service@newport.com

Europe
MICRO-CONTROLE Spectra-Physics S.A.S
9, rue du Bois Sauvage
91055 Évry CEDEX
France

Sales
Tel.: +33 (0)1.60.91.68.68
e-mail: france@newport-fr.com

Technical Support
e-mail: tech_europe@newport.com

Service & Returns
Tel.: +33 (0)2.38.40.51.55